

TAMILNADU FIRE AND RESCUE SERVICE

SCHOOL NO OBJECTION CERTIFICATE

R.C.NO: 307/V/SPR/2024

DATE:08.05.2025

Certificated that the **M/S.HAYAGRIVA VIDHYASHRAM SCHOOL**, at No:3, Car Street, Sriperumbudur Taluk, Kanchipuram District. comprised of Ground Floor and 2 Upper floor occupied by **M/s.HAYAGRIVA VIDHYASHRAM SCHOOL**, have Fire Service Rules, and verified by the officers concerned of Fire Service on 07/05/2025 in the presence of Principal, **M/s..HAYAGRIVA VIDHYASHRAM SCHOOL**, No:3, Car Street, Sriperumbudur Taluk, Kanchipuram District and that the building/premises is for occupancy School Premises with effect from 08/05/2025 for a period of 09/05/2026 Years in accordance with rule and subject to compliance of the conditions.

CONDITIONS



1. This License is valid for One year from the date of issue.
2. Fire Safety Systems should be maintained in good working condition.
3. Mock drill to be conducted periodically with the help of local fire brigade.
4. Any erection of permanent or temporary structure should be intimated to this department.
5. Further to limit the occupant load and to ensure better fire and life safety measures the following additional measures are insisted.
6. a) Building occupancy capacity should not be more than 4 people per Sq. meter as per The National Building Code-2016.
b) The staircase treads and flooring shall be treated with rough finish (Grooving) to Avoid falling of children.
c) As per Para 6.3 of the BIS Standards IS 14435:1997 as the Classrooms have only One entrance, the capacity of the class room shall have to be limited to 45 students.

To:

M/s.HAYAGRIVA VIDHYASHRAM SCHOOL,
No:3, Car Street,
Sriperumbudur Taluk,
Kanchipuram District

23 June 8/5/25
நிலைய அலுவலர்
தீயணைப்பு-மீட்டிப்பணி நிலையம்
மூப்பெரும்புதூர்-602 105

Copy to : District officer, Kanchipuram.