

TAMILNADU FIRE AND RESCUE SERVICE

SCHOOL NO OBJECTION CERTIFICATE

R.C.No: 145/V/Spr/2026

Date: 19.05.2026

Certified that the M/s: HAYAGRIVA VIDHYASHRAM SCHOOL, at No: 3, Car Street, Sriperumbudur Taluk, Kanchipuram District. Comprised of Ground Floor and 2 Upper Floor Occupied by M/s: HAYAGRIVA VIDHYASHRAM SCHOOL, have Fire Service Rules, and verified by the Officers concerned of Fire Service on 19.05.2026 in The Presence of Principal, M/s: HAYAGRIVA VIDHYASHRAM SCHOOL, No: 3, Car Street, Sriperumbudur Taluk, Kanchipuram District and that the Building/Prermisesis for Occupancy School Premises with effect from 19.05.2026 for a Period of 18.05.2027 Years in accordance with rule and subject to compliance of the Conditions.



CONDITIONS

1. This License is valid for One year from the date of issue.
2. Fire Safety Systems should be maintained in good working condition.
3. Mock drill to be conducted periodically with the help of local fire brigade.
4. Any erection of permanent or temporary structure should be intimated to this department.
5. Further to limit the occupant load and to ensure better fire and life safety measures the following additional measures are insisted.
 - a) Building occupancy capacity should not be more than 4 people per Sq. meter as per The National Building Code-2016.
 - b) The staircase treads and flooring shall be treated with rough finish (Grooving) to Avoid falling of children.
 - c) As per Para 6.3 of the BIS Standards IS 14435:1997 as the classrooms have only One entrance, the capacity of the class room shall have to be limited to 45 students

To,

M/s: HAYAGRIVA VIDHYASHRAM SCHOOL,
No: 3, Car Street,
Sriperumbudur Taluk,
Kanchipuram District.

Jk. 19/5/26
Station Officer,
Fire and Rescue Service,
Sriperumbudur.
(V. VADIVELU)

Copy to: District Officer, Kanchipuram.

For HAYAGRIVA VIDHYASHRAM SCHOOL

Correspondent

For HAYAGRIVA VIDHYASHRAM SCHOOL

Principal